



ZigBee Smart Energy Protocol

Implementation Conformance Statement

Manufacturer	Elster GmbH, Germany
Product Type	Gas Meter Comms Interface (UMI™ Peripheral)
Product Name	ECM ZigBee RF Dual
Firmware Revision	0.7.5
Smart Energy version	1.1

Disclaimer:

The information provided in this document can be made available to the general public in order to identify the tested versions, features and options.

By signing this document, the manufacturer confirms that all information provided in this document is correct and the applicable features have been tested.

Manufacturer name: Elster GmbH, Lotte (Germany)

Representative name and title: Joerg Kleine-Klatte
BU Gas International, R&D Residential Gas Metering
Head of Software Development

Signature:

Date:

A handwritten signature in blue ink, followed by the date '2011-10-24' also written in blue ink.

References

The following standards contain provisions, which, through reference in this document, constitute provisions of this standard. All the standards listed are normative references. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below.

1.1 ZigBee Alliance documents

- [R1] ZigBee document 053474r17: ZigBee Specification 2007
- [R2] ZigBee document 064321r08: ZigBee Stack Profile
- [R3] ZigBee document 074855r04: ZigBee PRO Stack Profile
- [R4] ZigBee document 075356r16: ZigBee Smart Energy Profile Specification
- [R5] ZigBee document 075123r03: ZigBee Cluster Library Specification
- [R6] ZigBee document 04300r08: ZigBee Network Layer PICS
- [R7] ZigBee document 064147r07: ZigBee Application Layer PICS
- [R8] ZigBee document 043171r04: ZigBee Security Layer PICS
- [R9] ZigBee document 064113r07: ZigBee Cluster Library PICS
- [R10] ZigBee document 11041: ZigBee SE 1.x Extensions for UK Rev. 2.0

1.2 IEEE documents

- [R11] IEEE Standard for Part 15.4: Wireless Medium Access Control (MAC) and Physical Layer (PHY) specifications for Low Rate Wireless Personal Area Networks (LR-WPANs), 2003.

1.3 ISO documents

- [R12] ISO/IEC 9646-1:1991, Information technology - Open Systems Interconnection - Conformance testing methodology and framework - Part 1: General concepts.
- [R13] ISO/IEC 9646-7:1995, Information technology - Open Systems Interconnection - Conformance testing methodology and framework - Part 7. Implementation conformance statements.

2 Abbreviations and special symbols

Notations for requirement status:

M	Mandatory
O	Optional
O.n	Optional, but support of at least one of the group of options labeled O.n is required.
N/A	Not applicable
X	Prohibited
<i>Item Number</i> : : <i>Status</i>	Status is conditional on support of item number

“*Item Number*”: Conditional, status dependent upon the support marked for the “*Item Number*”.

For example, FD1: O.1 indicates that the status is optional but at least one of the features described in FD1 is required to be implemented, if this implementation is to follow the standard of which this PICS Proforma is a part.

3 Identification of the implementation

Device under test (DUT) identification – Device to be certified as ZigBee SE 1.1 product

DUT manufacturer: Elster GmbH, Germany
DUT name: ECM ZigBee RF Dual
DUT version: Elster Firmware 0.7.5 / Ember ZNet 4.5.2 – SoC em375 / Hardware 201-B
DUT profile: Smart Energy 1.1

Additional: This DUT is the initial revision of a new product, it is not based on any existing product

Manufacturer Identification

Name: Elster GmbH
Address: Strotheweg 1, 49504 Lotte, Germany
Telephone number: +49 (0) 541 1214-0
Fax number: +49 (0) 541 1214-595

Contact information

Name: Joerg Kleine-Klatte
Telephone number: +49 (0) 541 1214-231
Email address: joerg.klatte@elster.com

System configuration under test (SUT) identification

SUT name: Electronic Index of Gas Meter BKG4-E
SUT version: Firmware 1.19.2 / Hardware Rev. F
Operating System: None

Product Marketing Description

The *ECM ZigBee RF Dual* is a peripheral communication module linked to a metrological host device according to the Universal Metering Interface (UMI™) specification. As such, it extends the Elster BKG4-E Gas Meter with a ZigBee Smart Energy 1.1 compliant HAN interface.

Name: _____

Signature: _____

4 Global statement of conformance

The implementation described in this PICS proforma meets all of the mandatory requirements of the referenced standards:

Application Profile: ZigBee SE – 075356r16

☒ Yes

☐ No

Note -- Answering 'No' indicates non-conformance to the specified protocol standard. Non-supported mandatory capabilities are to be identified in the following tables, with an explanation by the implementer explaining why the implementation is non-conforming.

The supplier will have fully complied with the requirements for a statement of conformance by completing the statement contained in this subclause. That means, by clicking the above, the statement of conformance is complete.

5 PICS proforma tables

The following tables are composed of the detailed questions to be answered, which make up the PICS proforma.

5.1 ZigBee Device Types

Table 1 - Functional device types

Item number	Item description	Reference	Status	Support
FDT1	Is this device capable of acting as a ZigBee coordinator?	[R1]/2.5.5.5.1	¹ O.1	NO
FDT2	Is this device capable of acting as a ZigBee router?	[R1]/2.5.5.5.2	O.1	NO
FDT3	Is this a ZigBee end device?	[R1]/2.5.5.5.3	O.1	YES

5.2 Stack Profile

Table 2 –Stack Profile

Item number	Item description	Reference	Status	Support
ZSP1	Is the device built on a ZigBee Compliant Platform certified for the ZigBee stack profile [R2]?	[R6] [R4]/5.2	O.2 ²	NO
ZSP2	Is the device built on a ZigBee PRO Compliant Platform certified for the ZigBee PRO stack profile [R3] ?	[R3] [R4]/5.2	O.2	YES

¹ O.1 – Device under test must select only one of these options. Devices under test supporting multiple ZigBee device types must serially re-test using each supported ZigBee device type.

² O.2 – Device under test must be deployed on either of the ZigBee or ZigBee PRO stack profiles.

5.3 Stack Profile extensions for SE

Table 3 – Stack profile extensions for SE

Item number	Item description	Reference	Status	Support
SPE1	Does the device support Application Link Keys?	[R4]/5.2 [R8]/ASLS6	M	YES
SPE2	Does this device use a stack that supports fragmentation?	[R4]/5.2 [R7]/ADF5, ADF6	M	YES
SPE3	Does this device use any SE Profile Commands that require the use of Fragmentation?	[R4]/5.2 [R7]/ADF5, ADF6	MC1: M: MS1: M	YES
SPE4	Does the device adhere to the polling rate specifications given in [R4]/5.2 (i.e. Does your application poll equal to or less often as called out in the specification)?	[R4]/5.2	FDT3:M	YES

5.4 SE general requirements support

Table 4 – SE general requirements support

Item number	Item description	Reference	Status	Support
AMG1	Does the device support the ZigBee Cluster Library?	[R4]/5.10, 5.11 [R5]	M	YES
AMG2	Does the device support the ZigBee Cluster Library List specified for SE including the mandatory/optional clusters detailed in the ZCL PICs?	[R4]/5.10 [R9]	M	YES
AMG3	Does the device support the ZigBee Cluster Library with the SE reporting configuration parameters?	[R4]/5.10 [R5]	M	YES

Item number	Item description	Reference	Status	Support
AMG4	Is the device capable of joining a ZigBee SE network and does it interact with a consumer ZigBee Home Area Network only through a bridge device?	[R4]/5.1	FDT2: M FDT3: M	YES
AMG5	Does the device support "E-Mode" commissioning? SE Profile requirement: Those devices that will join an existing network must support button pushes or simple documented user interfaces to initiate the joining process.	[R4]/5.1	FDT2: M FDT3: M For joining devices	YES
AMG6	Deleted	[R4]/5.1		N/A
AMG7	Does the device support the compatible Startup Attribute Set, Join Parameters, Security Parameters, End Device Parameters, Link Status Parameters, Concentrator Parameters, APS Transport Parameters and Binding Parameters?	[R4]/5.3, 5.3.1, 5.3.2, 5.3.3, 5.3.4, 5.3.5, 5.3.6, 5.3.7, 5.3.8, 5.3.9	M	YES
AMG8	Does the device support joining with pre-installed link keys?	[R4]/5.4.1	FDT2: M FDT3: M	YES
AMG9	Does the device support joining using the key establishment cluster?	[R4]/5.4.2	FDT2: M FDT3: M	YES
AMG10	Deleted	[R4]/5.5		N/A
AMG11	Does the device support the list of SE preferred channels?	[R4]/5.7.1	O	YES
AMG12	Does the device support the SE broadcast policy?	[R4]/5.7.2	O	YES
AMG13	Does the device support the SE frequency agility policy?	[R4]/5.7.3	O	YES
AMG14	Does the device support the security key update	[R4]/5.7.4	M	YES

Item number	Item description	Reference	Status	Support
	policies for SE networks?			
AMG15	Does the device support the ZCL Time Cluster and SE time synchronization?	[R4]/5.11.1.1	M	YES
AMG16	Does the device support discovery of optional attributes?	[R4]/5.10	M	YES
AMG17	Does the device application discover and handle unsupported attributes in other devices?	[R4]/5.10	M	YES
AMG18	Does the device support an indication to the user that the network has formed properly?	[R4]/5.5.1	O	NO
AMG19	Does the device support an indication to the user that a device has joined a network successfully?	[R4]/5.5.1	O	YES
AMG20	Does the device support the commissioning modes and provide supporting commissioning documentation according to network type?	[R4]/5.5.2, 5.5.3, 5.5.4	M	YES
AMG21	Does the device use the appropriate security key per cluster?	[R4]/5.4.6	M	YES

5.5 ZigBee SE device description support

Table 5 – SE device description support

Item number	Item description	Reference	Status	Support
AMD1	Is the product programmed as an Energy Service Portal?	[R4]/6.3.1	O.3 ³	NO
AMD2	Is the product programmed as a Metering Device?	[R4]/6.3.2	O.3	YES
AMD3	Is the product programmed as an In-Premise Display?	[R4]/6.3.3	O.3	NO

³ O.3 – Device under test must select at least one and may select more than one of the SE device descriptions. If multiple SE device descriptions are supported in the same device then each of the supported device descriptions must be deployed on individual endpoints within the device under test.

Item number	Item description	Reference	Status	Support
AMD4	Is the product programmed as a Programmable Communicating Thermostat (PCT)?	[R4]/6.3.4	O.3	NO
AMD5	Is the product programmed as a Load Control?	[R4]/6.3.5	O.3	NO
AMD6	Is the product programmed as a Range Extender?	[R4]/6.3.6	O.3	NO
AMD7	Is the product programmed as a Smart Appliance?	[R4]/6.3.7	O.3	NO
AMD8	Is the product programmed as a Prepayment Terminal?	[R4]/6.3.8	O.3	NO

5.6 AML common clusters

The common cluster ZCL PICs restrictions/requirements are obtained from [R4]/5.10, 5.11.

Table 6 – Common cluster ZCL PICs restrictions/requirements

ZCL PICs Item number [R9]	Status	Additional Constraints	Support
FC100	M	ZCL Cluster ID enumeration is mandatory	YES
FC1	M	General ZCL Frame Format is mandatory	YES
BCC1	O	Does the device support the Basic Cluster as a client?	YES
BCS1	M	Does the device support the Basic Cluster as a server?	YES
GCC1	O	Does the device support the Groups Cluster as a client?	NO
GCS1	O	Does the device support the Groups Cluster as a server?	NO
ACC1	O	Does the device support the Alarms Cluster as a client?	NO

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
ACS1	O	Does the device support the Alarms Cluster as a server?	NO
TCS1		Deleted	N/A
TCC1		Deleted	N/A

Table 7 – Common cluster support

Item number	Item description	Reference	Status	Support
ASDC1	Deleted	[R4]/5.10		N/A
ASDC2	Deleted	[R4]/5.10		N/A
ASDC3	Deleted	[R4]/5.10		N/A
ASDS1	Deleted		O	N/A
ASDS2	Does the device support the server Price Cluster sent via the Anonymous Inter-PAN transmission mechanism?	[R4]/Annex D.4	O	NO
ASDS3	Does the device support the server Message Cluster sent via the Anonymous Inter-PAN transmission mechanism?	[R4]/Annex D.5	O	NO
SCC1	Does the device support the Key Establishment cluster as a client?	[R4]/Annex C.3.1	FTD2:M FTD3:M	YES
SCS1	Does the device support the Key Establishment cluster as a server?	[R4]/Annex C.3.1	FTD1:M	YES
PC1	Does the device support the Price cluster as a client?	[R4]/5.10	O	YES
PS1	Does the device support the Price cluster as a server?	[R4]/5.10	O	NO

Item number	Item description	Reference	Status	Support
DRLC1	Does the device support the Demand Response and Load Control cluster as a client?	[R4]/5.10	O	NO
DRLS1	Does the device support the Demand Response and Load Control cluster as a server?	[R4]/5.10	O	NO
SMC1	Does the device support the Metering cluster as a client?	[R4]/5.10	O	YES
SMS1	Does the device support the Metering cluster as a server?	[R4]/5.10	O	YES
MC1	Does the device support the Message cluster as a client?	[R4]/5.10	O	NO
MS1	Does the device support the Message cluster as a server?	[R4]/5.10	O	NO
CMC1		[R4]/5.10	O	NO
CMS1		[R4]/5.10	O	NO
PPC1		[R4]/5.10	O	NO
PPS1		[R4]/5.10	O	NO
AMCC1		[R4]/7.1	O	NO
AMCC2	Are any manufacturer-specific cluster(s) supported?	[R4]/6.1.2	O	YES
	List of Manufacturer specific cluster(s) <ul style="list-style-type: none"> SSWG TOU Calender Client (ID 707h) SSWG Prepayment Server (ID 705h) 	[R10]	O	YES

5.7 ZigBee SE Device Description Capabilities

Tables in the following sub-clauses detail the capabilities specific to a device description.

5.7.1 Energy Service Portal device functions

Table 8 – Energy Service Portal ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
TCS1	M	Time Cluster server is mandatory	N/A

Table 9 provides the SE PICS restrictions based on requirements in [R4]/6.3.1.1.

Table 9 – Energy Service Portal SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
SMC1	O	Simple Metering Cluster client is optional	N/A
SMS1	O	Simple Metering Cluster server is optional	N/A
MS1	M	Message Cluster server is mandatory	N/A
PS1	M	Price Cluster server is mandatory	N/A
DRLS1	M	Demand Response and Load Cluster server is mandatory	N/A
PC1	O	Price Cluster client is optional	N/A
MS1	O	Message Cluster client is optional	N/A
PPC1	O	Pre-payment Cluster client is optional	N/A
PPS1	O	Pre-payment Cluster server is optional	N/A

5.7.2 Metering device functions

Table 10 – Metering device ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
TCC1	O	Time Cluster client is optional	YES

Table 11 provides the SE PICS restrictions based on requirements in [R4]/6.3.2.1.

Table 11 – Metering device SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
SMS1	M	Simple Metering Cluster server is mandatory	YES
CMS1	O	AMI Tunneling (Complex Metering) Cluster server is optional	NO
PPC1	O	Pre-payment Cluster client is optional	NO
PC1	O	Price Cluster client is optional	YES
MC1	O	Message Cluster client is optional	NO

5.7.3 In-Premise display device functions

Table 12 – In-Premise display device ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
TCC1	O	Time Cluster client is optional	N/A

Table 13 provides the SE PICS restrictions based on requirements in [R4]/6.3.3.1.

Table 13 – In-Premise display device SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
DRLC1	O	Demand Response and Load Cluster client is optional	N/A
PC1	O	Price Cluster client is optional	N/A
SMC1	O	Simple Metering Cluster client is optional	N/A
PPC1	O	Pre-payment Cluster client is optional	N/A
MC1	O	Message Cluster client is optional	N/A

5.7.4 Programmable Communicating Thermostat (PCT) device functions

Table 14 Programmable Communicating Thermostat (PCT) ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
TCC1	M	Time Cluster client is mandatory	N/A

Table 15 provides the SE PICs restrictions based on requirements in [R4]/6.3.4.1.

Table 15 Programmable Communicating Thermostat (PCT) SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
DRLC1	M	Demand Response and Load Cluster client is mandatory	N/A
PPC1	O	Pre-payment Cluster client is optional	N/A
PC1	O	Price Cluster client is optional	N/A
SMC1	O	Simple Metering Cluster client is optional	N/A
MC1	O	Message Cluster client is optional	N/A

5.7.5 Load Control device functions

Table 16 – Load Control ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
TCC1	M	Time Cluster client is mandatory	N/A

Table 17 provides the SE PICS restrictions based on requirements in [R4]/6.3.5.1.

Table 17 – Load Control SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
DRLC1	M	Demand Response and Load Cluster client is mandatory	N/A
PC1	O	Price Cluster client is optional	N/A

5.7.6 Range Extender device functions

Table 18 – Range Extender ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
			N/A

Table 19 provides the SE PICs restrictions based on requirements in [R4]/6.3.6.1.

Table 19 –Range Extender SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
			N/A

5.7.7 Smart Appliance device functions

Table 20 – Smart Appliance ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
TCC1	M	Time Cluster client is mandatory	N/A

Table 21 provides the SE PICs restrictions based on requirements in [R4]/6.3.7.1.

Table 21 –Smart Appliance SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
DRLC1	O	Demand Response and Load Cluster client is optional	N/A

AMI PICS Item number	Status	Additional Constraints	Support
PC1	M	Price Cluster client is mandatory	N/A
SMC1	O	Simple Metering Cluster client is optional ED NOTE: This is not listed in the specification – should it be?	N/A
MC1	O	Message Cluster client is optional	N/A

5.7.8 Prepayment Terminal device functions

Table 22 – Prepayment Terminal ZCL PICS restrictions/requirements

ZCL PICS Item number [R9]	Status	Additional Constraints	Support
TCC1	M	Time Cluster client is mandatory	N/A

Table 23 provides the SE PICS restrictions based on requirements in [R4]/6.3.8.1.

Table 23 – Per-payment Terminal SE PICS restrictions/requirements

AMI PICS Item number	Status	Additional Constraints	Support
DRLC1	O	Demand Response and Load Cluster client is optional	N/A
PC1	M	Price Cluster client is mandatory	N/A
SMC1	O	Simple Metering Cluster client is optional	N/A
MC1	O	Message Cluster client is optional	N/A

