

```
<cluster>
<name>Relative Humidity Measurement</name>
<code>0x0405</code>
<define>RELATIVE_HUMIDITY_MEASUREMENT_CLUSTER</define>
<attribute mandatory="true" name="measured value" source="server"
code="0x0000"
define="RELATIVE_HUMIDITY_MEASURED_VALUE"/> TRUE/FALSE
<attribute mandatory="true" name="min measured value" source="server"
code="0x0001" define="RELATIVE_HUMIDITY_MIN_MEASURED_VALUE"/>
TRUE/FALSE
<attribute mandatory="true" name="max measured value" source="server"
code="0x0002" define="RELATIVE_HUMIDITY_MAX_MEASURED_VALUE"/>
TRUE/FALSE
<attribute mandatory="false" name="tolerance" source="server" code="0x0003"
define="RELATIVE_HUMIDITY_TOLERANCE"/> TRUE/FALSE
</cluster>
```